

Er. N. KUPPARAO, M.E., F.I.V., M.I.E., C.E., M.Sc., Valuation

Class IA Gov. Registered Engineer, Issue Structural Stability Certificate for Public Buildings.

Chartered Engineer,

Bank Approved Engineer

Structural Engineer

Income Tax Valuer

128, Main Road,

Pudupalayam,

Cuddalore - 1.

Cell: 9367647047, 6380100567

Ref.No. 29/2026

Date: 01.06.2026

CERTIFICATE OF STRUCTURAL SOUNDNESS FOR THE SCHOOL

STATEMENT ACCOMPANYING FORM - A

1. Door Number of the building : **"SHRI RAM SCHOOL"**
2. Location (street name, ward no : New S.F.No.125/1A, 2, 3, 4, 5, 6, 7A, 8, 9
Name of place i.e.corporation 10A, 11A, 126/1, 2, 3, 4, 5, 6, 7, 8, 9, 10,
Municipality/ Panchayat/ 11, 12, 13, 14A, 15, 16A, 17A,
Panchayat Union/ Township/ Thenkodipakkam Village,
Cantonment, etc, Building Lies on S.F.No.300/2A, 2B, 3A,
Omandur Village, Thindivanam Taluk,
Villupuram District
3. Year of construction : 2014
4. Approximate cost of : Rs. 13,00,00,000/- (Thirteen Crores only)
construction as per current rates
5. Purpose for which the building : **Education purpose / Class Room for School**
is being used or proposed to be used
6. Purpose for which the building : **Education purpose / Class Room for School**
has hitherto been used
7. Detailed of construction the
Building (Particulars of the foundation
Soil, Specification of the Various parts
Under)
 - a) Foundation : RCC Framed Structure
 - b) Basement : RCC Column & Footings& Brick Masonry
 - c) Superstructure : Brick Masonry
 - d) Roof : RCC Roof
 - e) Floor Finishing :
 - i) Primary School Building : Special Stone Floor Finishing
 - ii) Secondary & Senior School Building : Ceramic Tiles Floor Finishing

N. KUPPARAO, ME., F.I.V., M.I.E.,
Class IA Registered engineer for Collectorate
Issue of Structural Soundness Certificate
128, Main Road, Pudupalayam,
CUDDALORE - 607 001. Cell : 9367647047

Er. N. KUPPARAO, M.E., F.I.V., M.I.E., C.E., M.Sc., Valuation

Class IA Gov. Registered Engineer, Issue Structural Stability Certificate for Public Buildings.

Chartered Engineer,

Bank Approved Engineer

Structural Engineer

Income Tax Valuer

128, Main Road,

Pudupalayam,

Cuddalore - 1.

Cell: 9367647047, 6380100567

f) Area of the Building :

Primary School Building

Ground Floor	-	912.60 Sq.M
First Floor	-	810.78 Sq.M
Second Floor	-	810.78 Sq.M
Terrace Floor	-	76.82 Sq.M

Secondary & Senior School Building

Ground Floor	-	1376.67 Sq.M
First Floor	-	1376.67 Sq.M
Second Floor	-	1376.67 Sq.M
Terrace Floor	-	218.78 Sq.M

Total - 6959.77 Sq.M

(Or) 74887.12 Sq.ft

8. Period for which license is Required : 3 Years (01.06.2026 to 31.05.2029)

9. Total life of the Building Estimated : 60 Years

10. Number of person to be Accommodated : 2000 Nos

N. 
N. KUPPARAO, M.E., F.I.V., M.I.E.,
Class IA Registered engineer for Collectorate
Issue of Structural Soundness Certificate
128, Main Road, Pudupalayam,
CUDDALORE - 607 001. Cell : 9367647047

Er. N. KUPPARAO, M.E., F.I.V., M.I.E., C.E., M.Sc., Valuation

Class IA Gov. Registered Engineer, Issue Structural Stability Certificate for Public Buildings.

Chartered Engineer,

Bank Approved Engineer

Structural Engineer

Income Tax Valuer

128, Main Road,

Pudupalayam,

Cuddalore - 1.

Cell: 9367647047, 6380100567

Certified that no addition or alteration has been made to the existing building ("SHRI RAM SCHOOL" (New S.F.No.125/1A,2,3,4, 5, 6, 7A, 8, 9, 10A, 11A, 126/1, 2, 3, 4, 5, 6, 7, 8, 9, 10, 11, 12, 13, 14A, 15, 16A, 17A, Thenkodipakkam Village, Building Lies on S.F.No.300/2A,2B,3A, Omandur Village, Thindivanam Taluk, Villupuram District) building or portion of a building for which this application has been made.

I undertake to obtain a fresh license in case any addition or alteration is made to the existing building or portion of building. I also undertake to obtain a fresh license if the purpose for which the license was granted for the use of the building or a portion of the building originally changed or altered subsequently.

Date : 01.06.2026


Signature of the owner of the Building

Date : 01.06.2026


Signature of the Registered Engineer

N. KUPPARAO, M.E., F.I.V., M.I.E.,
Class IA Registered engineer for Collectorate
Issue of Structural Soundness Certificate
128, Main Road, Pudupalayam,
CUDDALORE - 607 001. Cell : 9367647047.

Er. N. KUPPARAO, M.E., F.I.V., M.I.E., C.E., M.Sc., Valuation

Class IA Gov. Registered Engineer, Issue Structural Stability Certificate for Public Buildings.

Chartered Engineer,

Bank Approved Engineer

Structural Engineer

Income Tax Valuer

128, Main Road,

Pudupalayam,

Cuddalore – 1.

Cell: 9367647047, 6380100567

FORM – B

(Form of certificate of structural soundness under sub section 4 of the Tamil Nadu Public Building (Licensing) Act .1965 (Tamil Nadu Act.13 of 1965) referred to in rule 4 of the Tamil Nadu Public buildings (Licensing) Rule. 1966.)

I certify that I have inspected the building of **“SHRI RAM SCHOOL”**, (New S.F.No.125/1A,2,3,4, 5, 6, 7A, 8, 9, 10A, 11A, 126/1, 2, 3, 4, 5, 6, 7, 8, 9, 10, 11, 12, 13, 14A, 15, 16A, 17A, Thenkodipakkam Village, Building Lies on S.F.No.300/2A,2B,3A, Omandur Village, Thindivanam Taluk, Villupuram District), mentioned in the statement and furnish below its salient technical features, and the same is based on the data, measurements and specifications found in the site of the subject school physically.

I. Foundation

- | | |
|--|-----------------------------|
| 1. Depth below ground level | : 2.4 m |
| 2. Nature of soil not with at foundation level | : Hard Clay mixed with Lime |
| 3. Pressure at foundation | : 20.00 Ton/ Sq.M |
| 4. Probable safe bearing capacity of the soil met with at foundation | : 20.00 Ton/ Sq.M |

II. Super Structure:

- | | |
|--|--|
| 1. Maximum stress in the most critical section of masonry & concrete | : 30.00 Ton/ Sq.M |
| 2. Nature of masonry and concrete & its safe permissible stress | : Brick masonry with cement mortar 30.00 Ton/ Sq.M |

The Structural Soundness of the building has been verified by me with reference to ISI loading standards 878 (Latest Version) and other relevant Indian Standards Codes of practice and I declare that the building is structurally sound to be used as a public building for the purpose noted in the statement. A license may be granted for the period from 01.06.2026 to 31.05.2029

Date : 01.06.2026

N. 
Signature of the Engineer,

N. KUPPARAO, ME., F.I.V., M.I.E.,
Class IA Registered engineer for Collectorate
Issue of Structural Soundness Certificate
128, Main Road, Pudupalayam,
CUDDALORE - 607 001. Cell : 9367647047.

Er. N. KUPPARAO, M.E., F.I.V., M.I.E., C.E., M.Sc., Valuation

Class IA Gov. Registered Engineer, Issue Structural Stability Certificate for Public Buildings.

Chartered Engineer,

Bank Approved Engineer

Structural Engineer

Income Tax Valuer

128, Main Road,

Pudupalayam,

Cuddalore - 1.

Cell: 9367647047, 6380100567

FORM - C

**STATEMENT TO ACCOMPANY THE CERTIFICATE OF
STRUCTURAL SOUNDNESS**

1. Location of the building : **"SHRI RAM SCHOOL"**
(Door No, street Name & Name of the Place) : New S.F.No.125/1A, 2, 3, 4, 5, 6, 7A, 8, 9
10A, 11A, 126/1, 2, 3, 4, 5, 6, 7, 8, 9,
10, 11, 12, 13, 14A, 15, 16A, 17A,
Thenkodipakkam Village,
Building Lies on S.F.No.300/2A,2B,3A,
Omandur Village, Thindivanam Taluk,
Villupuram District
2. Age of the Building : 2014 (12 Years)
3. Number of Storeys : G.F+2 (Ground Floor, First Floor& Second Floor)
4. Short description of structures, : RCC Framed Structure
Steel R.C.C. Framed or load
bearing masonry
5. Purpose for which the building : **Education purpose / Class Room for School**
Certified for use
6. The period for which the building : 3 Years (01.06.2026 to 31.05.2029)
will be structurally sound
7. Number of persons to be : 2000 Nos
Accommodated
8. Remarks : The building is structurally sound stable strong
and fit for habitation

Date: 01.06.2026

N.

Signature of the Engineer

N. KUPPARAO, ME., F.I.V., M.I.E.,
Class IA Registered engineer for Collectorate
Issue of Structural Soundness Certificate
128, Main Road, Pudupalayam,
CUDDALORE - 607 001. Cell : 9367647047.

Er. N. KUPPARAO, M.E., F.I.V., M.I.E., C.E., M.Sc., Valuation

Class IA Gov. Registered Engineer, Issue Structural Stability Certificate for Public Buildings.

Chartered Engineer,

Bank Approved Engineer

Structural Engineer

Income Tax Valuer

128, Main Road,

Pudupalayam,

Cuddalore - 1.

Cell: 9367647047, 6380100567


Form - E

(Form of report to be made to the competent authority by inspecting authorities or officers appointed under other acts under Sec.28 of the Madras public Building (Licensing) Act 1965 (Madras Act 13 of 1965) referred to in rule 7 of the Madras public Building (Licensing) Rules 1966.)

1. Name and designation of the inspecting authority or officer appointed by or having jurisdiction under any other act or law : Er.N.KUPPARAO, M.E, M.I.E, F.I.V.,
Chartered Engineer (INDIA),
Class -1(A) Panel Registered Engineer
2. Location of the building & Name of the Place) : **"SHRI RAM SCHOOL"**

New S.F.No.125/1A, 2, 3, 4, 5, 6, 7A, 8, 9
10A, 11A, 126/1, 2, 3, 4, 5, 6, 7, 8, 9,
10, 11, 12, 13, 14A, 15, 16A, 17A,
Thenkodipakkam Village,
Building Lies on S.F.No.300/2A,2B,3A,
Omandur Village, Thindivanam Taluk,
Villupuram District
3. Date of inspection : 01.06.2026
4. Purpose for which the building certified for use : **Education purpose / Class Room for School**
5. Nature of defects noticed : Nil
6. Suggestion for rectifying defects : Nil
7. If in a dangerous condition immediate steps recommended to be taken : Nil

Date : 01.06.2026

N. 
Signature of the inspecting authority
officer appointed / having jurisdiction

N. KUPPARAO, M.E., F.I.V., M.I.E.,
Class IA Registered engineer for Collectorate
Issue of Structural Soundness Certificate
128, Main Road, Pudupalayam,
CUDDALORE - 607 001. Cell : 9367647047

Proceedings of the District Collector, Cuddalore

Present: Thiru.S.Suresh Kumar, I.A.S.

No.B1/9787/2013

Dated: 04.08.2015

Sub: Buildings - Tamil Nadu Public Buildings (Licensing) Act 1965 -Inclusion of Thiru.N.Kupparao in the Panel of Private Practicing Registered Engineers under Class 1A Category - Orders issued

Ref: 1) Application of Thiru. N.Kupparao of Cuddalore, dated 03.06.2013
2) The Superintending Engineer, PWD Buildings (C&M) Circle, Vellore , No. D2/F.20 P.E/2014/366-M, dated 18.09.2014
3) Engineer-in Chief (Buildings), Chief,Engineer (Buildings), Chennai Region, Chief Engineer(General),PWD, Chennai Lr.No. AEE/T1/AE /16550/2015, dated: 06.07.2015.

ORDER:

The name of Thiru.N.Kupparao, B.E, Chartered Engineer, No.73, Main Road, Adupalyam, Cuddalore-607 001, is included in the panel of Private Practicing Registered Engineers of Cuddalore District, maintained in this office with the approval of the Board of Engineers, as laid down under Class 1A (Monetary limit of Rs. 50/-Lakhs and above) after getting approval of Board of Engineers, Chennai as per G.O.Ms.No. 43, Municipal Administration and Water Supply (MA4) Department, dated 17-02-2011 for the issue of structural soundness certificate for Public Buildings under the Tamil Nadu Public Buildings (Licensing) Act 1965.

2) He is registered under the category of Class-1A Engineer (Buildings cost of which exceeds Rs.50.00 Lakhs)

Sd/- S.Suresh Kumar
Collector,
Cuddalore.

/t.c.b.o/

[Signature]
for Collector,
Cuddalore.

[Signature]
Thiru. N.Kupparao, B.E,
Chartered Engineer,
73, Main Road,
Adupalyam,
Cuddalore-607 001.

To Revenue Divisional Officer, Cuddalore/
Vandhachalam, & Sub Collector, Chidambaram
To All Tahsildars of Cuddalore District.
To B1 for Stock File